



Filing Receipt

Received - 2022-03-18 11:37:02 AM
Control Number - 52667
ItemNumber - 64



Officers:
Kyle Griffith, *President*
Jim Tarrant, Jr. *Vice-President*
Keith Youngblood, *Sec.-Tres.*
Greg Jones, *Manager*

Directors:
Wes Barron
Bruce Bradley
Wayne Shamblin
Rob Trimble III

PROJECT NO. 52667

Progress Filing on Compliance of
Cherokee County Electric Cooperative Association's Updating its
House Bill 4150 and PURA § 38.004(b) Compliance Report

March 18, 2022

Public Utility Commission Central Records

Attn: Filing Clerk

P.O. Box 13326

Austin, TX 78711-3326

RE: Project 52667 Filing related to Compliance Progress for Cherokee County Electric Cooperative Association ("CCECA")


Pursuant to a March 11, 2022 letter received by CCECA from the Division of Compliance and Enforcement of the Public Utility Commission of Texas ("PUC"), CCECA is submitting this update letter regarding its compliance efforts of any non-compliant distribution lines applicable to the requirements of HB 4150.

An update was required by today's date, and CCECA takes its public safety obligations and its obligations to the PUC seriously and as such, CCECA is filing this update letter.

While CCECA was not completely sure whether or not the three lines we listed in our previous filing in this docket were built to compliance standards at the time of construction, out of an abundance of caution, CCECA went ahead and brought all such lines into the NESC clearance standards in effect as of September 1, 2019.

Accordingly, as of March 11, 2022, CCECA is now in position to declare and confirm to the PUC that all distribution lines above 1 kilovolt owned by it that crosses a lake listed in PURA 38.004(b) meets the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).

Sincerely,


Chris Young, CCECA's Engineer